User Manual of AL8010H Thermostat

High-Temperature Controller

(Version 21.08.04GEN)

AL8010H thermostat owns one 30A output relay that controls the power supply status of the refrigerator or a heater, the set-point temperature range from 0 to 300 °C.

1. Package

Controller 1PCS
Fasteners 2PCS
Sensor 1PCS
Manual 1PCS
Waterproof Cover 1PCS

2. Specification

Input Power 220V AC \pm 10% 50/60HZ; (12/24/48/110V Option)

Maximum current 30A (Default) under 220V AC

Sensor NTC, 25° C /100 K Ω , the sensor cable 200cm

Protection Class IP65 to the front panel

Storage $-10^{\circ}\text{C} \sim 60^{\circ}\text{C}$, RH<90%, without condensation

Measurable Range $0^{\circ}\text{C} \sim 300^{\circ}\text{C}$ Controllable Range $0^{\circ}\text{C} \sim 300^{\circ}\text{C}$

Resolution 1°C Accuracy: \pm 1°C Power Consumption \leq 3W


3. Interface & Operation


3.1. Front Panel & Icon

Under normal status

• When screen light, Hold the Rst key

for 3s to turn off the controller;






3.2. Indicator / Character in Display

Indicator	Meaning	On	Hide	Wink
Work	Working status of the load	Load Working	Stop	Delay
Set	Setting status	On Set	Non-setting	N/A

3.3. Dimensions & Installation




- A. Suggested amount dimension: 71*29*85mm (W*H*D)
- B. Detach the slide clips, put the controller into the hole, wiring follow the diagram
- C. Install the fasteners and the waterproof cover.
- D. Please avoid installing in the below environments:
 - Relative humidity > 90%, have condensation
 - The places that temperature <-10°C or >60°C;
 - The places that have inflammable and explosives;
 - Strong vibration or struck
 - Exposed to the continuous water mist spraying;
 - Exposed to the dust;
 - Exposure to corrosive and pollution gas (e.g., the gas, smoke, or salt fog);
 - Wireless electromagnetic interference or strong magnetic fields (near to transmitting antenna or switch board room);


3.4. Wiring Diagram

The input power voltage of the load and the controller could be different.

Same



Different



- A. 100K NTC sensor, need not distinguish + or when wiring it.
- B. The input voltage must be within the range of Marked Voltage $\pm 10\%$.
- C. Load Power $\leq \frac{\text{The voltage of load} * \text{Max current of Relay}}{\text{Factor}}$
 - The factor for Inductive Load like compressor, heating pump, usually be 5~8;
 - The factor for Resistive Load like Electric heating rod, Electric blanket usually is 1.5~2;
 - The factor for Incandescent lamps usually is 15.

4. Configurations

4.1. Code and Function Menu

Code	Function	Min	Max	Default	Unit
HE	Refrigeration or Heating Mode	, contraction	H		O. HOLL
Ь	Temperature Hysteresis / Return Difference		15	,iii ,iii 5	°C
L5	Lower Limit for SP	0	SP	0	°C
H5	Upper Limit for SP	SP	300	50	°C
EA	Temperature Calibration	-5	+5	0	°C
PE	Protection Delay Time for Refrigeration	~~~~ 0	×6 ×6 0		Min

4.2. What is SP, and how to set it?

SP means <u>Set Point</u>, from <u>SP - Hysteresis</u> to $\underline{SP + Hysteresis}$ is the range user wish temperature keep around, once exceed this range the status of the load will be changed, Details of setting as follow

Step1 Assure power on, press the set key, you will find display show a changeable value, **default SP = 10°C.**

Step2 Now press the □ or □ keys to get your aim value;

- Press and hold on the \(\bigsim\) or \(\bigsim\) is fast forward function;
- The step length is 1°C;
- The editable range between the lower (L5) and the higher (H5) limit.

Sten3 Hold on 10s; the device will save data automatically or press to save it.

4.3. When will the load start/stop work?

- A. In the heating mode (HL = H), the Relay will turn on the heater when Measured Temperature Value \leq SP Temp. Hysteresis (d)
- B. In the refrigeration mode ($H \subseteq \Gamma$), the Relay will turn on the compressor when
 - a) the time should be later than the compressor last stops moment + PE
 - b) Measured Temperature Value ≥ SP + Temp. Hysteresis (d)

4.4. How to correct measured temperature?

Exist gap/distance between the measured temperature and the actual temperature is very common, especially the first time you launch this controller; the gaps could be corrected by setting the value in [A. = Actual Temp - Measured.

4.5. How to set other parameters?

- Step1 Hold set for 3s, and you will see the code HE.
- **Step2** Press □ or □ keys to select the code you want to update,
- Step3 Press the set to see the existing value and Press the or key to change the value;
- Step4 Press the Rst key to back to the function menu list;

Repeat operation from Step 2 / 3 / 4 to adjust other parameters;

Step5 After configuring all values, Remember to press the key to save data and back to normal monitor status, in which you can check values (ref. 6.1).

Attention the modified value will be saved automatically and back to normal status if without operation in 10 seconds.

4.6. How to get Factory Reset?

In normal status, Hold the and keys simultaneously for 8s; the screen will show 45, which means success.

5. Error & Alarm

When alarming occurred, the error code in the display will not disappear until fixed all problems.

Code	Reason	Troubleshooting	
1105 17	Sensor error or open circuit	Ensure the sensor was installed firmly or replace a new sensor, display back to normal in 15 seconds once the problem is fixed.	
HHH Measured temperature > H5 or sensor short circuit		Check the room temperature and then change the compressor/heater working status manually.	
LLL	Measured temperature < L5		

6. Environmental Information



The packing material is 100% recyclable. Just dispose of it through specialized recyclers.

The electro components can be recycled if it is disassembled for specialized companies.

Please do not burn or throw the controllers in domestic garbage. Observe the respective law in your region concerning the environmentally responsible manner of disposing of its devices.

Haswill Electronic https://www.thermo-hygro.com/

Copyright Haswill & Haswell All Rights Reserved

